



G.D. Mills Plumbing & Heating

Homeowner Gas Safety Record

Cert. No. 546

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

Company / Installer

Engineer

Company

Address

Post Code

Tel No.

Gas Safe Reg

ID Card No.

Gary Mills

G.D. Mills Plumbing & Heating

11

High Street

Loanhead

Midlothian

EH20 9RH

07515353474

3951

4748528

Job Address

Name

Address

Post Code

Tel. No

Paolo Mazzone

151/1

Bruntsfield Place

Edinburgh

EH10 4EB

Customer / Landlord

Name

Company

Address

Post Code

Tel. No

Mr James Baxter

7

Findhorn Place

Edinburgh

EH9 2JR

Appliance Details						Inspection Details														
	Location	Appliance Type	Make	Model	Flue Type	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
									Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Kitchen	Hob	Lamona	LAM1006	OF	Yes	20.09	7.889	-	-	-	-	-	-	Yes	Yes	NA	NA	No	Yes
2	Kitchen	Central Heating Boiler	Vaillant	EcoTec Plus 835	RS	Yes	14.12	36.131	0.0009	68	9.1	0.0000	5	9.1	Yes	Yes	Yes	Pass	Yes	Yes
3																				
4																				
5																				
6																				

Defects / Identified

1

2

3

4

5

6

NA

NA

Labels and Warning Notice Issued

CO Alarm(s)

CO Alarm(s) fitted

CO Alarm(s) tested and Satisfactory

Yes

Pass

Smoke Alarm(s)

Smoke Alarm(s) fitted

Smoke Alarm(s) tested and Satisfactory

Yes

Pass

Emergency Control Accessible Yes

Gas Tightness Satisfactory Yes

Gas Installation Pipework Visual Inspection Satisfactory Yes

Equipotential Bonding Yes

NEXT INSPECTION DUE ON OR BEFORE

19-Oct-2023

Comments

Signatures

Issued by:

Signed

Print Name

Gary Mills

Received by:

Signed

Print Name

Paolo Mazzone

Date

19-Oct-2022