

Fire Detection and Alarm System Inspection and Servicing Report

RECORD NUMBER

261025F

COMPANY/ENGINEER

Engineer **DEREK FULTON**
Company **CONLEY ELECTRICAL**
Reg No.
Address **9/2 NORMFIELD
BROADWAY EDIN.**
Postcode **EH8 7GF** Tel No
Email **07894809616**

CUSTOMER/LANDLORD

Name **JAMES BAXTER**
Address **FINDHORN PLACE
EDINBURGH.**
Postcode **EH9** Tel No
Email **07811335040**

SITE ADDRESS

Name **TENANTED FLAT**
Address **FLAT 4
163 BRUNTSFIELD PLACE
EDINBURGH**
Postcode **EH10** Tel No
Email

3. EXTENT OF THE INSTALLATION AND LIMITATIONS OF THE INSPECTION AND SERVICING

Extent of the fire detection and alarm system covered by this report:

**INTERLINKED MAINS SYSTEM
COMPRISING OF SMOKE AND HEAT DETECTORS
ALL OPERATIONAL/ALL TEST BUTTONS FUNCTIONING**

Agreed and operational limitations of the inspection and servicing (including reasons and person agreed with):

NONE

5. CERTIFICATION OF INSPECTION AND SERVICING

I/we being the competent person(s) responsible (as indicated by my/our signatures below) for the servicing of the fire detection and alarm system, particulars of which are set out below. CERTIFY that the said work for which I/we have been responsible complies to the best of my/our knowledge and belief with the recommendations of Clause 45 of BS 5839-1:2017 quarterly inspection of vented batteries periodic inspection and test/inspection over a 12 month period, except for the variations, if any, stated in this certificate.


Variations from the recommendations of Clause 45 of BS 5839-1:2017 for periodic or annual inspection and test (as applicable):

NONE

The extent of liability of the signatory/signatories is limited to the system described above.

For the INSPECTION and SERVICING of the system:

Signature



Date

3/10/25

6. SUMMARY OF THE INSPECTION AND SERVICING

See page 3 for a summary of the general condition of the fire detection and alarm system

Overall assessment of the inspection and servicing in term of its suitability for continued use*: **SATISFACTORY**

*An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified.