

6 W/P CRESC

MAINS

Fire Detection and Fire Alarm System

Commissioning Certificate

BS 5839-1: 2013 H.3

ANNUAL MAINTENANCE
CHECK

Details of the Client

Client: JAMES BAXTER
 Address: FINDHORN PLACE, EDIN.
 Postcode:

Details of the Fire Detection and Fire Alarm System

Address: 6 WARRENDER PARK CRESCENT
 EDIN. Postcode:

Extent of
system

covered by

this certificate:

MAINS INTERCONNECTED
 SYSTEM (11 HEADS)

The system is:

~~NEW EXISTING~~ ☒Modification: ☐

System Examinations and Recommendations

Tick box(es) or insert N/A (Not Applicable) as appropriate.

☒ All equipment operates correctly☒ Installation work is, as far as can be reasonably ascertained, of an acceptable standard☒ The entire system has been inspected and tested in accordance with the recommendations of Clause 39.2c of BS 5839-1: 2013

The system performs as required by the specification prepared by:

N/A.

a copy of which I/we have been given

☒ Taking into account the guidance contained in Section 3 of BS 5839-1: 2013, I/we have not identified any obvious potential for an unacceptable rate of false alarms.☒ The documentation described in Clause 40 of BS 5839-1: 2013 has been provided to the user

The following work should be completed before/after (delete as appropriate) the system becomes operational

NONE

The following potential causes of false alarms should be considered at the time of the next service visit

NONE

Before the system becomes operational, it should be soak tested in accordance with the recommendations of Clause 35.2.6 of BS 5839-1: 2013 for a period of:

N/A.

weeks

(Enter a period of at least one week, or as defined by the designer whichever is the greatest, or insert N/A if not applicable.)

Certification of Commissioning

I being the competent person responsible (as indicated by my signature below) for the commissioning of the fire detection and fire alarm system, particulars of which are set out above, CERTIFY that the said work for which I have been responsible complies to the best of my/our knowledge and belief with the recommendations of Clause 39 of BS 5839-1: 2013 except for the variations, if any, stated in this certificate:

Variations from the recommendations of Clause 39 of BS 5839-1: 2013 (see Clause 7).

(Continue on additional numbered pages as required)

The extent of liability of the signatory is limited to the system described above

For the COMMISSIONING of the System:

Name (CAPITALS): D FULTON Position: ELECTRICIAN (APP)
 Signature: [Signature] Date: 25/10/16

Particulars of the company commissioning the system:

Company Name: COMEY ELECTRICAL
 Address: 1 DEWFIELD WAY EDIN. Postcode: EH15 2BL

Design Specification and Related Reference Documents

Design Specification

Ref No: Date Issued

Design Drawings

Ref No: Date Issued

'As Fitted'

Drawing Nos: Date Issued

Electrical Installation Certificate No. for fire alarm supply:

Date Issued

Fire Alarm Design

Certificate No: Date Issued

Fire Alarm Installation

Certificate No: Date Issued