

FIRE ALARM SYSTEM VERIFICATION CERTIFICATE

Certificate of verification for the system at : JAMES BAXTER
(TENANT'S FLAT)

Address : 163(2F2) BRUNTSFIELD PLACE, EDINBURGH

I being the competent person responsible (as indicated by my signature below) for the verification of the fire alarm system. Particulars of which are set below, CERTIFY that the verification work for which I have been responsible for complies to the best of knowledge and belief with the recommendations of Clause 43 of BS 5839-1 :2002.

Name (in block letters) : DEREK FULTON

Position : ELECTRICIAN (APP)

Signature : [Signature] Date : 29/10/19

For and behalf of : CONLEY ELECTRICAL
1 BELLFIELD LANE
EDINBURGH
EH15 2BL

The extent of liability of the signatory is limited to the system described below.

Extent of system covered by this certificate : MAINS INTERCONNECTED
SYSTEM C/W SMOKE & HEAT DETECTORS.

Scope and extent of the verification work : TESTED ALL DETECTORS
& INTERLINKING (BATTERYS LITHIUM-7 YEARS LEFT)

☒ In my opinion that as far as can reasonably be ascertained from the scope of work described above. The system complies with has been commissioned in accordance with the commendations of BS 5839-1 : 2002. Other than in respect of variations already identified in the certificates of design, installation or commissioning.

☒ In my/our opinion there is no obvious potential for an unacceptable rate of false alarms. The following non-compliances with the recommendation of BS 5839- 1 : 2002, have been identified. (other than those recorded as variations in the certificate of design, installation or commissioning) :

NONE