



FORTH FIRE PROTECTION

FIRE PROTECTION ENGINEERS & CONSULTANTS

Unit 9B, BONNINGTON IND. EST., NEWHAVEN ROAD, EDINBURGH EH6 5PY

Tel: 0131-553 5608/9 Fax: 0131-553 7554 Email: info@forthfireprotection.co.uk

INSPECTION REPORT No: B327

Name : Mr Baxter Properties

Address: 145 4F2 Bruntsfield Place, Edinburgh

The servicing of the Fire Fighting Equipment in the above named premises was carried out on the 26/10/2021 We have pleasure in detailing below our report.

Discharge testing in accordance with BS 5306 part 3 was/was not authorised. N/A

Location	SH	Type of Appliance	Year	S	R	H	D.T	O	Additional Remarks
Main entrance		Forth 2 Kilo ABC Dry Powder	2019	S				-	DTR 19
Kitchen		Fire Blanket							Inspected

Code: S - Serviced.

R – Recharged.

H – Hydraulic Tested etc.

D. T. – Discharge Tested.

O – O Rings / Washers fitted in accordance with BS 5306 part 3 2017